

# Town of West Tisbury

---

## Installation of Post & Marine Grade Rope Handrail

Project: 02142022

### ADDENDUM 1

**Extension of Time for Due Date:** Bids are now due on Monday, March 21<sup>st</sup> at 2:00 pm

#### Questions:

**Q:** *What overall length are the posts?*

**A:** Six Feet

**Q:** What nominal size are the posts? It is unclear if they are to be 4" x 4" or 4" x 6".

**A:** 3.5" x 5.5"

**Q:** *Please confirm bidders are to base their bid on cedar for the species of wood.*

**A:** Mahogany or Cedar can be used

**Q:** *Is there a specified grade for the timber?*

**A:** Minimum #2

**Q:** *Please provide a spec and/or a picture of the stainless steel brackets that are specified.*

**A:** This Bracket is an example of what the town is looking for:

[https://www.amazon.com/dp/B089T5VTXX/ref=cm\\_sw\\_r\\_sms\\_api\\_glt\\_i\\_B6RGPYZ12Y9CNGQY1Q5N?psc=1](https://www.amazon.com/dp/B089T5VTXX/ref=cm_sw_r_sms_api_glt_i_B6RGPYZ12Y9CNGQY1Q5N?psc=1)

**Q:** *With the above mentioned brackets, do the posts need to be drilled for the 1.5" rope to be threaded through?*

**A:** The rope will be threaded through the bracket

**Q:** *Please confirm the completion date can be extended until the beginning of June if there are delays in material procurement.*

**A:** Extension available upon written request

**Q:** *Is there an order of conditions on the project from the conservation commission?*

**A:** No